

# Potable Water and Sanitary Sewer Engineer's Report

For

*440 Warehouse Developers LLC*

*Proposed Warehouse Development  
NJSH Route 440 & NJSH Route 185  
Block 30305, Lots 2, 3, 4 & 5  
City of Jersey City  
Hudson County, NJ*

Prepared By:



245 Main Street, Suite 110  
Chester, NJ 07930  
(908) 879-9229

A handwritten signature in black ink, appearing to read 'JCS', is written over a horizontal line.

Joseph C. Sparone, PE, PP  
NJ Professional Engineer License #47204

October 2021  
DEC #3783-99-001

## TABLE OF CONTENTS

	<u>Page</u>
I. INTRODUCTION	2
II. PROPOSED SANITARY SEWERAGE FACILITIES	2
III. SANITARY SEWER PIPE DESIGN	2
IV. PROPOSED WATER SYSTEM FACILITIES	3

## APPENDIX

- Capacity of Circular Pipe Flowing  $\frac{1}{2}$  Full
- Sewer Capacity Requirements Calculation
- Water Demand Requirements Calculation

## ***I. INTRODUCTION***

The intention of this study is to analyze the sanitary sewer and water demands that will occur as a result of the proposed warehouse development consisting of the construction of a 2-story warehouse building with associated multi-story office, parking structures, and associated ramps and driveways. The subject site is located at Route 440 & Route 185, City of Jersey City, Hudson County, New Jersey. The site is identified as Block 30305, Lots 2, 3, 4, and 5 on the Jersey City Tax Maps. The site is currently fully developed with an aboveground storage tank facility featuring nine (9) storage tanks and ancillary structures which will be removed to allow for the proposed redevelopment.

## ***II. PROPOSED SANITARY SEWERAGE FACILITIES***

The proposed sanitary sewer facilities for the warehouse and office consist of 6" PVC gravity lateral which will connect to a proposed onsite pump station. The pump station will discharge sewerage via a 2" force main that will extend to the existing 18" JCMUA sanitary sewer trunk line located within the NJDOT right-of-way.

The estimated domestic sanitary sewer demand for the warehouse and office as per NJAC 7:14A-23.3 is as follows:

Office Space = 0.1 gallons/day (GPD) per square foot

Warehouse = 25 gallons/day (GPD) per employee

Office Space = 82,271 SF X 0.1 GPD = 8,227 GPD

Warehouse Space = 250 employees X 25 GPD/employee = 6,250 GPD

TOTAL = 14,477 gallons/day (GPD)

The pump station design will be provided by others. Details of same will be provided prior to construction.

## ***III. SANITARY SEWER PIPE DESIGN***

Per NJDEP regulations, the criteria for establishing the size of gravity sanitary sewer is to convey two times the average daily flow with the pipe flowing half full. Utilizing Manning's Equation with a roughness coefficient of 0.010 for PVC pipe, the following is the minimum capacity of the proposed sanitary sewer mains and laterals:

Pipe Size	Min. Slope	Roughness (n)	Capacity at 1/2 Full	ADF	2 X ADF
6"	2.08%	0.010	340,000 gpd	14,477 gpd	28,954 gpd

#### ***IV. PROPOSED WATER SYSTEM FACILITIES***

Domestic and fire water service to the buildings will be provided via a 10" water main that will connect to the existing 12" JCMUA water main stub within Route 440.

The installation of water service facilities will be coordinated with and under the guidelines, regulations and specifications of the Jersey City Municipal Utilities Authority. The estimated water demand for the warehouse facilities and office, as per NJAC 7:10-12.6 Water Volume Requirements, is as follows:

##### Domestic Water Demand:

Office Space = 0.125 gallons/day (GPD) per square foot

Warehouse = 25 gallons/day (GPD) per employee

Office Space = 82,271 SF X 0.125 GPD = 10,284 GPD

Warehouse Development = 250 employees X 25 GPD/employee = 6,250 GPD

TOTAL = 16,534 gallons/day (GPD)

##### Fire Water Demand:

The Facility will require 2,000GPM

## **APPENDIX**

## **CAPACITY OF CIRCULAR PIPE FLOWING AT $\frac{1}{2}$ FULL**

Manning's Equation

Design Parameters:

Pipe Diameter, $D$ .....	6 in
Pipe Material .....	PVC
Slope, $s$ .....	2.08 %
Flow Depth, $y$ .....	HALF

Calculations:

Cross-Sectional Area, $A = D^2/8 [\theta - \sin(\theta)] =$ .....	0.10 ft <sup>2</sup>
Manning's Coefficient, $n$ .....	0.010
Hydraulic Radius, $R$ .....	0.13 ft
Angle, $\theta =$ .....	3.14 radians
Wetted Perimeter, $P = \theta D/2$ .....	0.79 ft
Flow Depth, $y$ .....	0.25 ft
Flow Top Width, $T = 2[y(D-y)]^{1/2}$ .....	0.50 ft
Gravity Constant, $g$ .....	32.174 ft/s <sup>2</sup>
Froude Number, $F$ .....	2.13


**Supercritical Flow**

• Flow & Velocity:


Flow,  $Q_o = \frac{1.486 \cdot R^{2/3} s^{1/2} A}{n}$  ..... **0.53 cfs**  
**0.34 MGD**

Velocity,  $V = Q/A$  ..... **5.36 fps**

Cross-Section of Culvert



Cut-away Side View



$$Q = VA \quad V = \frac{k}{n} R^{2/3} S^{1/2} \quad R = \frac{A}{P} \quad A = \frac{d^2}{8} (\theta - \sin(\theta))$$

$$P = \frac{\theta d}{2} \quad y = \frac{d}{2} \left[ 1 - \cos\left(\frac{\theta}{2}\right) \right] \quad T = 2\sqrt{y(d-y)} \quad F = V \sqrt{\frac{T}{gA \cos(\tan^{-1} S)}}$$

# **ESTIMATED SANITARY SEWER FLOW CALCULATIONS**



Date: 9/30/2021  
Project: MCR 54 Rte 440, LLC  
Project No: 3783-99-001

Calculated By: SDP  
Checked By: RJC

Sanitary Sewer Flow Analysis

**Projected Sanitary Sewer Flow Criteria [N.J.A.C. 7:14A-23.3]**

Industrial	25 GPD/Emp
Office	0.10 GPD/SF

**PROPOSED CONDITIONS:**

<b>Use:</b>	<b>Units</b>	<b>Flow (GPD)</b>
Warehouse	250 Employee	6,250
Office	82,270 SF	8,227

<b>Total Proposed Flow:</b>	<b>14,477 GPD</b>
-----------------------------	-------------------

**Notes:**

1. Existing & Proposed flows based on Projected Sanitary Sewer Flow Criteria [N.J.A.C. 7:14A-23.3].

## **ESTIMATED WATER DEMAND CALCULATIONS**



Date: 9/30/2021  
Project: MCR 54 Rte 440 LLC  
Project No: 3783-99-001

Calculated By: SDP  
Checked By: RJC

Water Flow Analysis

**Projected Water Demand Generation [N.J.A.C. 7:10-12.6(b)2]**

Industrial 25 GPD/8-hr shift  
Office 0.125 GPD/SF

**PROPOSED CONDITIONS:**

<b>Use:</b>	<b>Units</b>	<b>Flow (GPD)</b>
Warehouse	250 Employee	6,250
Office	82,270 SF	10,284

<b>Total Proposed Flow:</b>	<b>16,534 GPD</b>
-----------------------------	-------------------

**Notes:**

1. Existing & Proposed flows based on Average Daily Water Demand [N.J.A.C. 7:10-12.6(b)2 - Table 1].